



HPi Verification Services

Type Examination Certificate

This is to certify that the product listed below conforms to the requirements of the

Pressure Equipment Directive

97/23/EC Annex III Module B

Certificate Number

HPiVS/P4042-137-I-01 rev. 2

Date of Issue

05-Set-2022

Date of Expiry

05-Set-2029

Designer

Yacht Space srl
Via Buozzi 40/42
48026 Russi (RA) / Italy

Description of Pressure Equipment

Portable Nano Particles Disposable Fire Extinguisher
Type: Athos Nano

Serial No

Not applicable

Design Pressure

PS: 12 bar (min burst tests 120 bar)

Design Temperature

-20 to 60 °C

This Certificate is valid in any European Economic Area Member State.

This Certificate has been issued by HPi Verification Services Ltd which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive.

This Certificate is issued following the assessment of a representative sample of the Pressure Equipment detailed above in accordance with the provisions of the above regulations. The equipment must be subject to an appropriate conformity assessment module during manufacture prior to the CE Mark being affixed.

Managing Director

Technical Director



Tel +44 1491 822818
Fax +44 700 600 6831
Email enquiries@eucertification.com
www.eucertification.com

HPi Verification Services Ltd.
The Manor House
Howbery Park, Wallingford
OX10 8BA, United Kingdom